

M_. _____ introduced the following resolution and moved its passage:

RESOLUTION NO. ____
AUTHORIZING AGREEMENT WITH STATE SECURITY, LLC, FOR
THE FIRE ALARM REPLACEMENT PROJECT

The Superintendent recommends approval of an agreement with State Security, LLC as being in the best interest of the District for the purchase and installation of a replacement fire alarm system in the High School located at 555 South Old 3C Road, Sunbury, Ohio.

Rationale:

1. The Board has identified a need to replace the fire alarm system in the High School for the safety and protection of persons and school property ("Project").
2. The purchase and installation of the Project is outside the scope of the competitive bidding requirements provided in R.C. 3313.46 as the Project is for the safety and protection of school property.
3. The Board solicited competitive proposals for the Project, the proposal provided by State Security being the lowest in the amount of \$58,300.00.

The Board of Education resolves as follows:

1. The Board determines the Project to be outside of the competitive bidding requirements of R.C. 3313.46, as it is for the safety and protection of school property.
2. The Board authorizes the Superintendent and Treasurer to work with legal counsel to negotiate an agreement with State Security, LLC in an amount not to exceed \$58,300 and to execute the agreement and any related documents on the Board's behalf.

M_. _____ seconded the motion and, after discussion, a roll call vote was taken and the results were:

Ayes: _____ Nays: _____

The resolution passed.



Proposal

April 29, 2022

Mike Neff

mike.neff@state-security.com

614-206-6794

Big Walnut Local School District Big Walnut High School Fire Alarm Panel Replacement

Scope of work:

State Security to replace the Simplex fire alarm panel at the High School. State Security to replace like for like Firelite (nonproprietary) equipment throughout the building. There will be no additional devices added or removed from the new system. The fire alarm panel will stay in the same location. This proposal does not take into account any changes or adds that the State of Ohio or the AHJ may request. All devices will be new and installed in exact locations as original devices on existing wire. Along with the fire alarm devices the AV system (horn strobes and strobes) must be replaced. The system as it stands now does not sync which is required by code. By not upgrading now the new fire inspection would fail upon a permitted life safety. Ste Security will obtain a workable set of drawings to produce engineered stamped drawings for filing with the State of Ohio.

Fire Alarm System:

1-Firelite ES200x Fire Alarm Panel
2-Firelite Annunciator Keypads
37-Firelite Addressable Pull Stations
21-Addressable Firelite Smoke Detectors
4-FCPS Power Supplies
24-Addressable Monitoring Modules to Monitor Water Flows, Tamper Switches and Duct Detectors
9-Addressable Smoke Duct Detectors with Sampling Tubes and remote test stations
110-AV Devices (Horn Strobes/Strobes)
1-Engineered stamped drawings*
1-Fire Alarm Permit
1-Life Safety/Witness Test
Total Cost \$58,300.00

*District to provide workable drawings for fire device placement on engineered drawings. Cost will increase if drawings need to be created from scratch.